

## ABOVE GROUND BULK TANK INFORMATION SHEET March 2020



Failure to adhere to these instructions may delay or prevent your tank installation

### ABOVE GROUND BULK TANK OPTIONS

[Four Seasons Fuel Ltd](#) offer a range of above ground tanks suitable for different applications and consumptions.

Below is the specification for each of our aboveground bulk tanks to suit your requirements. Please note, each tank has a maximum fill capacity of 85%.

For more information please contact customer support on [01403 783379](tel:01403783379)



#### 600KG TANK

Application:  
Domestic homes for heating and light commercial heating applications.  
Capacity 600KG Propane

Tank Size Litres	1410 l
Siting Distance	3 m
Siting Distance if Firewall	1.5 m

Dimensions:	
Length	2012 mm
Height	1300 mm
Diameter	1000 mm



#### 1000KG TANK

Application:  
Higher usage domestic homes for heating and light commercial heating applications.  
Capacity 1000KG.

Tank Size Litres	2200 l
Siting Distance	3 m
Siting Distance if Firewall	1.5 m

Dimensions:	
Length	3042 mm
Height	1300 mm
Diameter	1000 mm

To be used as guidance only and subject to site survey



#### **2000KG TANK**

##### **Application:**

Higher usage domestic homes for heating and lighting, metered estates and large commercial usage

Capacity 2000KG.

Tank Size Litres	4600 l
Siting Distance	7.5 m
Siting Distance if Firewall	4.0 m

##### **Dimensions:**

Length	4388 mm
Height	1650 mm
Diameter	1200 mm

### **PREPARATION OF CIVIL WORKS**

Please note you will be asked to provide the concrete base and pipework trench for aboveground tanks.

The pipe trench needs to be **100 mm wide by 600 mm deep**. The concrete base and excavation dimensions are detailed in the table below:

<b>Tank Size</b>	<b>Concrete Base (mm)</b>
500 kg / 1410 l	2000L, 1000W, 150H
1000 kg / 2220 l	3100L, 1000W, 150H
2000 kg / 4600 l	4400L, 1200W, 150H

### **DELIVERY VEHICLE ACCESS**

The tanker delivery requires the vessel to be within 30 meters from the point of filling, while filling the driver must have line of sight between the tanker and vessel.

The minimum gate access width is 2.8M, while the main access road needs to be 3M in width.

Failure to adhere to these instructions may delay or prevent your tank installation

Please do not hesitate to contact Four Seasons Fuel Ltd for any additional information.

